

- 2. This is to be a private facility, governed by *UPC*, *NFPA*, *Oregon Dept. of Human Services* and Fire Marshal, as applicable.
- 3. Vault door mechanisms shall not project below the ceiling of the vault interior.
- 4. For fire line sizes 8-inches and larger, consult with city cross connection inspector for additional vault details.

CENTER UNITED IN CONTRACTOR OF THE PARTY OF	ENGINEERING DEPARTMENT		PRIVATE COMBINATION FIRE SERVICE VAULT & DOMESTIC DOUBLE CHECK		
	UTILITIES ENGINEER	DATE		DRAWN BY	DRAWING NO.
City Of Beaverton	David A. Winship, P.E.	6 - 10 - 04		CDH - WD	672